



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION
11805 SW 26 Street, Room 208
T (786) 315-2590 F (786) 315-2599

www.miamidade.gov/economy

N.R. Architectural Products, Inc.
4348 Westroads Drive
West Palm Beach, FL 33407

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone.

DESCRIPTION: Series "NRAP 2500-FX" Aluminum Fixed Window – L.M.I.

APPROVAL DOCUMENT: Drawing No. AD12-05, titled "NRAP Series 2500 Fixed Window (L.M.I.)", sheets 1 through 7 of 7, dated 02/20/12, with revision #1 dated 02/26/12, prepared by MCY Engineering, Inc., signed and sealed by Yiping Wang, P.E., bearing the Miami-Dade County Product Control Revision stamp with the Notice of Acceptance number and expiration date by the Miami-Dade County Product Control Section.

MISSILE IMPACT RATING: Large and Small Missile Impact Resistant

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state, model/series, and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA# 09-0519.01 and consists of this page 1 and evidence pages E-1 and E-2, as well as approval document mentioned above.

The submitted documentation was reviewed by Manuel Perez, P.E.



Handwritten signature and date: 7/7/13

NOA No. 12-0619.01
Expiration Date: August 19, 2014
Approval Date: July 11, 2013
Page 1

N.R. Architectural Products, Inc.

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

A. DRAWINGS

1. Manufacturer's die drawings and sections.
2. Drawing No **AD12-05**, titled "NRAP Series 2500 Fixed Window (L.M.I.)", sheets 1 through 7 of 7, dated 02/20/12, with revision#1 dated 02/26/12, prepared by MCY Engineering, Inc., signed and sealed by Yiping Wang, P. E.

B. TESTS

1. Test reports on: 1) Air Infiltration Test, per FBC, TAS 202-94
2) Uniform Static Air Pressure Test, Loading per FBC TAS 202-94
3) Water Resistance Test, per FBC, TAS 202-94
4) Large Missile Impact Test per FBC, TAS 201-94
5) Cyclic Wind Pressure Loading per FBC, TAS 203-94
6) Forced Entry Test, per FBC 2411 3.2.1, TAS 202-94
along with marked-up drawings and installation diagram of casement out- & fixed window system, prepared by Hurricane Testing Laboratory, Inc., Test Report No. **HTL 0242-0207-09**, dated 04/23/09, signed and sealed by Vinu J. Abraham, P.E.
(Submitted under previous NOA# 09-0519.01)

C. CALCULATIONS


1. Anchor calculations and structural analysis, complying with FBC-2010, dated 06/04/12, prepared by MCY Engineering, Inc., signed and sealed by Yiping Wang, P.E.
2. Glazing complies with ASTM E1300-04

D. QUALITY ASSURANCE

1. Miami-Dade Department of Regulatory and Economic Resources (RER)

E. MATERIAL CERTIFICATIONS

1. Notice of Acceptance No. **11-0624.02** issued to **E.I. DuPont DeNemours & Co., Inc.** for their "**DuPont SentryGlas® Interlayer**" dated 08/25/11, expiring on 01/14/17.
2. TREMCO Part No. **TR-PS1126E** EPDM exterior glazing gasket complying with ASTM C864 Option II exceptions, ASTM D412 1600 PSI, D395B 22 HRS 158°F.


Manuel Perez, P.E.
Product Control Examiner
NOA No. 12-0619.01
Expiration Date: August 19, 2014
Approval Date: July 11, 2013

N.R. Architectural Products, Inc.


NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

F. STATEMENTS

1. Statement letter of conformance, complying with FBC-2010, dated June 04, 2012, issued by MCY Engineering, Inc., signed and sealed by Yiping Wang, P.E.
2. Statement letter of no financial interest, dated June 04, 2012, issued by MCY Engineering, Inc., signed and sealed by Yiping Wang, P.E.
3. Laboratory compliance letter for Test Report No. **HTL 0242-0207-09**, issued by Hurricane Test Laboratory, Inc., dated April 07, 2009, signed and sealed by Vinu J. Abraham, P.E.
(Submitted under previous NOA# 09-0519.01)
4. Notification of Successor Engineer for manufacturer's NOA document per **Section 61G15-27.001** of the **Florida Administrative Code**, notifying original engineer that the successor engineer is assuming full professional and legal responsibility for all engineering documents pertaining to this NOA, dated April 24, 2012, signed and sealed by Yiping Wang, P.E.

G. OTHER

1. Notice of Acceptance No. **09-0519.01**, issued to NR Architectural Products for their Series "NRAP 2500-FX" Aluminum Fixed Window – L.M.I., approved on 08/19/09 and expiring on 08/19/14.


Manuel Perez, P.E.
Product Control Examiner
NOA No. 12-0619.01


Expiration Date: August 19, 2014
Approval Date: July 11, 2013

GENERAL NOTES: FLORIDA BUILDING CODE

- 1- CODE: THIS PRODUCT HAS BEEN TESTED AND DESIGNED IN ACCORDANCE WITH THE FLORIDA BUILDING CODE 2010 INCLUDING THE HIGH VELOCITY HURRICANE ZONE (HVHZ).
- 2- DEFINITION: THIS PRODUCT IS A FIXED TYPE WINDOW DESIGNED, CONSTRUCTED AND TESTED TO PROVIDE PROTECTION FROM HURRICANE FORCE WINDS AND WIND BORNE DEBRIS (LARGE MISSILE) WITHIN THE ALLOWABLE DESIGNED PRESSURES AND LIMITATIONS STATED IN THIS APPROVAL. INSTALLATION OF HURRICANE PROTECTION DEVICES IS NOT REQUIRED.
- 3- POSTING:
- NR ARCHITECTURAL PRODUCTS, INC.
WEST PALM BEACH - FLORIDA
MIAMI-DADE COUNTY PRODUCT CONTROL APPROVED
- 4- DESIGN LOADS: THE DESIGNED LOADS MUST BE CALCULATED BY A PROFESSIONAL ARCHITECT OR ENGINEER FOR EACH SPECIFIC PROJECT. THE CALCULATED DESIGNED PRESSURE MUST NOT EXCEED THE ALLOWABLE WINDOW PRESSURE.
- 5- MATERIAL: GLAZING TO BE IMPACT LAMINATED GLASS AS SPECIFIED ON THIS APPROVAL.
- 6- FASTENERS: ASSEMBLY SCREWS AND ANCHORS SHALL BE AS SPECIFIED IN THE CURRENT SET OF DRAWINGS. INSTALLATION AND LOADS AS PER THIS APPROVAL. ANCHOR QUANTITY & SPACING MUST NOT EXCEED THE MAXIMUM LIMITS SPECIFIED BY THIS APPROVAL.
- 7- USE: IT SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR, ARCHITECT OR ENGINEER OF RECORD TO VERIFY THE FOLLOWING:
- 7.1- THE STABILITY OF THE STRUCTURE WHERE THE PRODUCT IS TO BE ATTACHED INSURING PROPER ANCHORAGE.
- 7.2- THE SITE SPECIFIC PROJECT CRITERIA, SUCH AS BUT NOT LIMITED TO, LOCAL CODE REQUIREMENTS, DESIGNED PRESSURES ETC.
- 7.3- THAT THIS APPROVAL IS ADEQUATE TO THE SPECIFIC PROJECT.
- 8- 33 1/3% INCREASE IN ALLOWABLE LOADS HAVE NOT BEEN USED IN THE DESIGN OF THE ANCHORS FOR THIS PRODUCT APPROVAL, HOWEVER, WOOD SCREWS WITH 1.6 INCREASE FOR WIND LOAD DURATION HAVE BEEN USED.
- 9- DISSIMILAR MATERIALS: MATERIALS, INCLUDING BUT NOT LIMITED TO STEEL, THAT COME IN CONTACT WITH OTHER DISSIMILAR MATERIALS SHALL MEET THE REQUIREMENTS OF 2010 FLORIDA BUILDING CODE.


FOR ALLOWABLE SIZES AND PRESSURES REFER TO:
SHEET 2

TYPICAL ELEVATIONS
VIEW FROM OUTSIDE



(O) SINGLE
FIXED WINDOW
SEE SHEET 2 FOR RATING

(OO, OOO, OOOO)
MULTIPLE FIXED WINDOWS
SEE SHEET 2 FOR RATING



(XO, XOX, OXO, OXXOX)
MULTIPLE COMBINATION OF CASEMENT OUT AND FIXED WINDOWS
SEE SHEET 2 FOR RATING

TABLE OF CONTENTS:

SHEET	DESCRIPTION
1 of 7	GENERAL NOTES, INDEX AND TYPICAL ELEVATIONS
2 of 7	TABLE 1 & 2 DESIGN RATING FOR SINGLE AND MULTIPLES UNITS
3 of 7	TYPICAL DETAILS
4 of 7	ANCHORAGE LAY-OUT WITH STRAPS
5 of 7	ANCHORAGE LAY-OUT WITH SHEAR CLIP
6 of 7	WINDOW COMPONENTS AND BILL OF MATERIAL
7 of 7	GLAZING DETAILS & CORNER ASSEMBLY

PRODUCT REVISED
as complying with the Florida
Building Code
Acceptance No 12-0619.01
Expiration Date Aug 19, 2014
By *Maurice Perez*
Miami Dade Product Control

YIPING WANG, P.E.
FLORIDA REGISTRATION
PE #55983
C.A.N. 28677

Yiping Wang

REVISIONS
NO. DATE DESCRIPTION
1 02/20/12 UPDATED FOR FBC 2010

MCY
MCY ENGINEERING, INC.
GLAZING CONSULTANTS
8501 SW 124 AVE. STE. 205A P: 305.271.0117
MIAMI, FL 33183 F: 786.573.5063
www.MCYEngineering.com MCY.Engineering@Att.net


NRAP SERIES 2500 FIXED WINDOW (L.M.I.)
NR ARCHITECTURAL PRODUCTS
4348 WESTROADS DRIVE
WEST PALM BEACH, FL 33407
P: (561) 844 - 1121 F: (561) 844 - 6131

DATE 02-20-12
SCALE AS NOTED
DRAWN S.L.
PROJECT 12-028
DRAWING NO. AD12-05
SHEET 1 of 7

TABLE 1
DESIGNED RATING FOR
SINGLE FIXED UNITS (PSF)

MAX. FRAME WIDTH (FW)	MAX. FRAME HEIGHT (FH)	PRESSURES EXT (+) INT (-)
24	96	120
32	72	120
38.75	60	120
44	52	120
48	48	120
52	44	120
60	38.75	120
72	32	120
96	24	120

* FRAME WIDTH AND HEIGHT
IN INCHES
* PRESSURES IN PSF
* WINDOW AREA MUST NOT
EXCEED 16.15 SQFT
DLO=FW-4.375 OR FH-4.375




(D) SINGLE
FIXED WINDOW

TABLE 2
DESIGNED RATING FOR MULLIONS
ON MULTIPLE FIXED OR/AND
FIXED/CASEMENT UNITS (PSF)


TM	FH	MULL TYPE 6/ 8/ 10/ 10A EXT(+) INT(-)
24	60	120
32	60	120
38.75	60	120
44	52	120
48	48	120
54	43	120
60	39	120
66	35	120
72	32	120

TM- MAXIMUM TRIBUTARY
MODULE WIDTH IN INCHES
FH- MAXIMUM FINISHED HEIGHT
IN INCHES
PRESSURES IN PSF
DLO=FW-4.375 OR FH-4.375



$$TM = (FW1 + FW2) / 2$$


ALLOWABLE PRESSURE
BASED ON THE MIN.
PRESSURE FROM
TABLE 1 & 2




$$TM = (FW1 + FW2) / 2$$

ALLOWABLE PRESSURE
BASED ON THE MIN.
PRESSURE FROM
TABLE 1, 2 AND
CASEMENT WINDOW
APPROVAL.


10 STACK MULLION
FIXED/ FIXED




8 STACK MULLION
FIXED/ CASEMENT



10A STACK MULLION
CASEMENT/ FIXED
WHEN COMBINED WITH MULL 6



6 CAS-FIX MULLION
CASEMENT/ FIXED



PRODUCT REVISED
as complying with the Florida
Building Code
Acceptance No. 12-0619.01
Expiration Date 12-19-2014
By *Yiping Wang*
Miami Dade Product Control

YIPING WANG, P.E.
FLORIDA REGISTRATION
PE #55983
C.A.N. 28677

Yiping Wang

REVISIONS	NO.	DATE	DESCRIPTION
1	02/26/12	UPDATED FOR FBC 2010	

MCY ENGINEERING, INC.
GLAZING CONSULTANTS
8501 SW 124 AVE. STE. 205A
MIAMI, FL 33183
P: 305.271.0117
F: 786.573.5063
www.MCYEngineering.com
MCY.Engineering@Att.net

NRAP SERIES 2500 FIXED WINDOW (L.M.I.)
NR ARCHITECTURAL PRODUCTS
4348 WESTROADS DRIVE
WEST PALM BEACH, FL 33407
P: (561) 844 - 1121 F: (561) 844 - 6131






DATE	02-20-12
SCALE	AS NOTED
DRAWN	S.L.
PROJECT	12-026

DRAWING NO.
AD12-05

SHEET 2 of 7

JUN 14 2012

TYPICAL DETAILS



PRODUCT REVISED
as complying with the Florida
Building Code
Acceptance No 12-069.01
Expiration Date Aug 19, 2014
By *Manuel Perez*
Miami Dade Product Control

YIPING WANG, P.E.
FLORIDA REGISTRATION
PE #55983
C.A.N. 28677

Yiping Wang


REVISIONS		NO. DATE		DESCRIPTION	
1	02/28/12	1	02/28/12	UPDATED FOR FEB 2010	

MCY		MCY ENGINEERING, INC.		GLAZING CONSULTANTS	
8501 SW 124 AVE. STE. 205A		P: 305.271.0117		F: 786.573.5063	
MIAMI, FL 33183		www.MCYEngineering.com		MCY.Engineering@Att.net	


NRAP SERIES 2500 FIXED WINDOW (L.M.I.)		NR ARCHITECTURAL PRODUCTS	
4348 WESTROADS DRIVE		WEST PALM BEACH, FL 33407	
P: (561) 844 - 1121		F: (561) 844 - 6131	

DATE	02-20-12
SCALE	AS NOTED
DRAWN	S.L.
PROJECT	12-028
DRAWING NO.	AD12-05
SHEET	3 of 7

TYPICAL MAX.
ANCHOR SPACING




TYPICAL MAX.
ANCHOR SPACING




ANCHORAGE LAY-OUT WITH STRAP

TYPE	DESCRIPTION	PENETRATION	EDGE DIST.	SUBSTRATUM
A	1/4" TAPCONS	1 1/4"	2-1/2"	MASONRY OR CONCRETE
B	1/4" TAPCONS	1 1/2"	3/4"	INTO 2X BUCK (G>=0.55)
C	1/4-14 SDS	1/8"	1/2"	6063-T6 ALUMINUM ASTM A36 STEEL


TYPE A
1/4" TAPCONS WITH 1 1/4"
PENETRATION INTO CONCRETE
SPACED AS PER ELEVATION



TYPE B
1/4" TAPCONS WITH 1 1/2"
PENETRATION INTO 2X BUCK
SPACED AS PER ELEVATION
ANCHORS MUST BE MIN. 3"
OFFSET FROM 2X BUCK ANCHORS




2X BUCK ANCHORAGE TO
BE DESIGNED BY OTHERS




2X PRESSURE TREATED
SOUTHERN PINE G>=0.55

TYPE A
1/4" TAPCONS WITH 1 1/4"
PENETRATION INTO MASONRY
SPACED AS PER ELEVATION
ANCHORS MUST BE MIN. 3"
OFFSET FROM 1X BUCK ANCHORS




1X BUCK ANCHORAGE TO
BE DESIGNED BY OTHERS



1X PRESSURE TREATED
SOUTHERN PINE G>=0.55

TYPE C
1/4"-14X1" GRADE 5 SDS
INTO METAL STRUCTURES
SPACED AS PER ELEVATION



1/4-14x1 1/2" SDS
INTO MIN. 1/8"
METAL STRUCTURES
STEEL: MIN. ASTM A36
ALUMINUM: MIN. 6063-T6

YIPING WANG, P.E.
FLORIDA REGISTRATION
PE #55983
C.A.N. 28677

Yip Wang

ALL WOOD IN CONTACT WITH
MASONRY OR CONCRETE IS TO
BE PROTECTED PER FBC 2326

NO.	DATE	DESCRIPTION
1	02/25/12	UPDATED FOR FBC 2010

MCY ENGINEERING, INC.
GLAZING CONSULTANTS
8501 SW 124 AVE. STE. 205A
MIAMI, FL 33183
P: 305.271.0117
F: 786.573.5063
www.MCYEngineering.com
MCY.Engineering@Att.net

NRAP SERIES 2500 FIXED WINDOW (L.M.I.)
NR ARCHITECTURAL PRODUCTS
4348 WESTROADS DRIVE
WEST PALM BEACH, FL 33407
P: (561) 844-1121 F: (561) 844-6131


PRODUCT REVISED
as complying with the Florida
Building Code
Acceptance No. 12-0619.01
Expiration Date 04.19.2014
By *Manuel J. [Signature]*
Miami Dade Product Control

DATE	02-20-12
SCALE	AS NOTED
DRAWN	S.L.
PROJECT	12-025

DRAWING NO.
AD12-05



SHEET 4 of 7

JUN 14 2012




ANCHORAGE LAY-OUT WITH SHEAR CLIP.

TYPE	DESCRIPTION	PENETRATION	EDGE DIST.	SUBSTRATUM
A	1/4" TAPCONS	1 1/4"	2-1/2"	MASONRY OR CONCRETE
B	1/4" TAPCONS	1 1/2"	3/4"	INTO 2X BUCK (G>=0.55)
C	1/4-14 SDS	1/8"	1/2"	6063-T6 ALUMINUM ASTM A36 STEEL




1X BUCK ANCHORAGE TO BE DESIGNED BY OTHERS



ALL WOOD IN CONTACT WITH MASONRY OR CONCRETE IS TO BE PROTECTED PER FBC 2326

1/4"-14X2" SELF DRILLING SCREWS INTO METAL STRUCTURES SPACED AS PER ELEVATION



1/4-14x1 1/2" SDS INTO MIN. 1/8" METAL STRUCTURES
STEEL: MIN. ASTM A36
ALUMINUM: MIN. 6063-T6

PRODUCT REVISED as complying with the Florida Building Code
Acceptance No. 12-0619-01
Expiration Date Aug. 19, 2014
By *Manuel S. J...*
Miami Dade Product Control

YIPING WANG, P.E.
FLORIDA REGISTRATION
PE #55983
C.A.N. 28677

Yip Wang

NO.	DATE	DESCRIPTION
1	02/26/12	UPDATED FOR FBC 2010

MCY ENGINEERING, INC.
GLAZING CONSULTANTS
8501 SW 124 AVE. STE. 205A
MIAMI, FL 33183
P: 305.271.0117
F: 786.573.5063
www.MCYEngineering.com
MCY.Engineering@Att.net


NRAP SERIES 2500 FIXED WINDOW (L.M.I.)
NR ARCHITECTURAL PRODUCTS
4348 WESTROADS DRIVE
WEST PALM BEACH, FL 33407
P: (561) 844-1121 F: (561) 844-6131

DATE	02-20-12
SCALE	AS NOTED
DRAWN	S.L.
PROJECT	12-028


DRAWING NO.
AD12-05

SHEET 5 of 7

JUN 14 2012




1/4" TAPCONS WITH 1 1/4" PENETRATION INTO CONCRETE SPACED AS PER ELEVATION




ANCHORAGE LAY-OUT WITH SHEAR CLIP

TYPE	DESCRIPTION	PENETRATION	EDGE DIST.	SUBSTRATUM
A	1/4" TAPCONS	1 1/4"	2-1/2"	MASONRY OR CONCRETE
B	1/4" TAPCONS	1 1/2"	3/4"	INTO 2X BUCK (G)=0.55
C	1/4-14 SDS	1/8"	1/2"	6063-T6 ALUMINUM ASTM A36 STEEL




1X BUCK ANCHORAGE TO BE DESIGNED BY OTHERS



1X PRESSURE TREATED SOUTHERN PINE G=0.55

ALL WOOD IN CONTACT WITH MASONRY OR CONCRETE IS TO BE PROTECTED PER FBC 2326

1/4"-14X2" SELF DRILLING SCREWS INTO METAL STRUCTURES SPACED AS PER ELEVATION



1/4-14x1 1/2" SDS INTO MIN. 1/8" METAL STRUCTURES
STEEL: MIN. ASTM A36
ALUMINUM: MIN. 6063-T6

PRODUCT REVISED
as complying with the Florida Building Code
Acceptance No. 12-0619-01
Expiration Date Aug. 19, 2014
By *Maurice J. Wang*
Miami Dade Product Control

YIPING WANG, P.E.
FLORIDA REGISTRATION
PE #55983
C.A.N. 28677

Yip Wang

NO.	DATE	DESCRIPTION
1	02/20/12	UPDATED FOR FBC 2010

MCY ENGINEERING, INC.
GLAZING CONSULTANTS
8501 SW 124 AVE. STE. 205A
MIAMI, FL 33183
P: 305.271.0117
F: 786.573.5063
www.MCYEngineering.com
MCY.Engineering@Att.net

NRAP SERIES 2500 FIXED WINDOW (L.M.I.)
NR ARCHITECTURAL PRODUCTS
4348 WESTROADS DRIVE
WEST PALM BEACH, FL 33407
P: (561) 844-1121 F: (561) 844-6131

DATE	02-20-12
SCALE	AS NOTED
DRAWN	S.L.
PROJECT	12-028

DRAWING NO.
AD12-05












SHEET 5 of 7

JUN 14 2012

WINDOW COMPONENTS

COMPONENTS LIST

ITEM	PART#	DESCRIPTION	MATERIAL	SUPPLIER
1	PC-001	HEAD BASE FRAME (FIXED)	ALUMINUM 6063-T6	NR ARCHITECTURAL PRODUCTS
4	PC-004	BASE FRAME ADAPTOR	ALUMINUM 6063-T6	NR ARCHITECTURAL PRODUCTS
11	PC-011	SILL BASE FRAME (FIXED/OPERABLE)	ALUMINUM 6063-T6	NR ARCHITECTURAL PRODUCTS
14	PC-014	VERTICAL BASE FRAME (OPERABLE)	ALUMINUM 6063-T6	NR ARCHITECTURAL PRODUCTS
16	PC-016	GLASS STOP	ALUMINUM 6063-T6	NR ARCHITECTURAL PRODUCTS
18	PC-018	ALTERNATE STRAP ANCHOR	ALUMINUM 6063-T6	NR ARCHITECTURAL PRODUCTS
19	PC-019	STRAP ANCHOR	ALUMINUM 6063-T6	NR ARCHITECTURAL PRODUCTS
20	PC-020	STRAP ANCHOR COVER	ALUMINUM 6063-T6	NR ARCHITECTURAL PRODUCTS
21	PC-021	CONCEALED MULLION	ALUMINUM 6063-T6	NR ARCHITECTURAL PRODUCTS
22	PC-022	REINFORCEMENT CLIP	ALUMINUM 6063-T6	NR ARCHITECTURAL PRODUCTS
23	PC-023	CONCEALED STRAP ANCHOR	ALUMINUM 6063-T6	NR ARCHITECTURAL PRODUCTS
34	--	9/16" LAMINATED IMPACT GLASS	GLASS	DUPONT
36	NR-A24	VK2526 1/4" PVC SPACER	PVC	CAPITAL TAPE
37	--	GLAZING SEALANT DOW 983 II PART	SILICONE	DOW CORNING
38	--	GLAZING SEALANT DOW 995	SILICONE	DOW CORNING
39	NR-G20	PS 1126E POLY-WEDGE GASKET	70 DURE EPDM	TREMO
40	NR-G21	EXT. WEATHERSEAL AP 150	EXTRUDED TAPE	SCHLEGEL
41	NR-G22	INT. WEATHERSEAL TLOK 150	POLYETHYLENE	SCHLEGEL
43	NR-G25	GLASS SETTING BLOCK TR-1365E	70 DURE EPDM	TREMO
44	--	PERIMETER SEALANT DOW 795	SILICONE	DOW CORNING
45	--	FRAME JOINT SEALANT	SILICONE	CRL BUILDING PRODUCTS
46	NR-F12	BASE FRAME FIXING SCREWS	STAINLESS STEEL	#10X1 PPH TSEK SCREW
47	NR-F13	ADAPTOR FIXING SCREW	STAINLESS STEEL	#12 X 3/4" PP TEK SREW
48	NR-EP1	1/16"-2-1/2"X5/16" END PLATE	6063-T6 ALUMINUM	NR ARCHITECTURAL PRODUCTS



PRODUCT REVISED
as complying with the Florida
Building Code
Acceptance No. 12-0619-01
Expiration Date Aug 13, 2014
By *Yiping Wang*
Miami Trade Product Control

YIPING WANG, P.E.
FLORIDA REGISTRATION
PE #55983
C.A.N. 28677

DATE	02-20-12
SCALE	AS NOTED
DRAWN	S.L.
PROJECT	12-026

DRAWING NO.
AD12-05

SHEET 6 of 7

MCY ENGINEERING, INC.
GLAZING CONSULTANTS

8501 SW 124 AVE. STE. 205A
MIAMI, FL 33183

P: 305.271.0117
F: 786.573.5063

www.MCYEngineering.com

MCY.Engineering@Att.net

REVISIONS

NO.	DATE	DESCRIPTION
1	02/20/12	UPDATED FOR FBC 2010




NRAP SERIES 2500 FIXED WINDOW (L.M.I.)

NR ARCHITECTURAL PRODUCTS

4948 WESTROADS DRIVE
WEST PALM BEACH, FL 33407

P: (561) 844-1121 F: (561) 844-6131

JUN 14 2012




PRODUCT REVISED
as complying with the Florida
Building Code
Acceptance No 12-0619-01
Expiration Date Aug 17, 2014
By *Manuel Garcia*
Miami Dade Product Control

YIPING WANG, P.E.
FLORIDA REGISTRATION
PE #55983
C.A.N. 28677

Yip Wang

NO.	DATE	DESCRIPTION
1	02/26/12	UPDATED FOR FBC 2010



MCY ENGINEERING, INC.
GLAZING CONSULTANTS

8501 SW 124 AVE. STE. 205A
MIAMI, FL 33183
P: 305.271.0117
F: 786.573.5063

www.MCYEngineering.com
MCY.Engineering@att.net

NRAP SERIES 2500 FIXED WINDOW (L.M.I.)

NR ARCHITECTURAL PRODUCTS

4348 WESTROADS DRIVE
WEST PALM BEACH, FL 33407
P: (561) 844 - 1121 F: (561) 844 - 6131

DATE	02-20-12
SCALE	AS NOTED
DRAWN	S.L.
PROJECT	12-026

DRAWING NO.
AD12-05

SHEET 7 of 7

JUN 14 2012